

**AIR RESOURCES BOARD**

2020 L STREET  
P.O. BOX 2815  
SACRAMENTO, CA 95812



September 20, 1994

Mr. Jim Asbury  
Manager: Total Quality  
Catlow Incorporated  
2750 U.S. Route 40  
Tipp City, Ohio 45371

#94-23

Dear Mr. Asbury:

Approval of the OPW Model 28CI Conversion Fitting

You requested California Air Resources Board (CARB) approval of the OPW Model 28CI Conversion Fitting. The OPW 28CI fitting is manufactured by Catlow Incorporated as the Catlow Model 200BI Conversion Fitting, and was approved by CARB on September 12, 1994. It is listed in Approval Letter #94-20.

The OPW Model 28CI is a cast aluminum conversion fitting adaptor intended for use at the outlet of a multi-product gasoline dispensing device to convert the dispenser outlet connection from a standard coaxial type connection to inverted metric 34 thread (M34) coaxial connection. The unit shall be installed in conformity to the manufacturer's instructions and all applicable codes. The 28CI Conversion Fitting shall, as required by the California State Fire Marshal (CSFM), bear the CSFM Seal of Certification and the Underwriters Laboratories (UL) Mark.

CARB requires the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals for the Catlow 200BI fitting have previously been obtained from these agencies.

Based on the fact that the OPW 28CI Conversion Fitting is the same fitting which was certified as the Catlow 200BI, I find that its use, when installed in accordance with the manufacturer's instructions and the conditions listed above, will not adversely affect the performance of vapor recovery systems on which it is installed. Therefore, the OPW Model 28CI Conversion Fitting is certified for use with Phase II vapor recovery systems.


Mr. Jim Asbury

-2-

September 20, 1994

Should you have any questions or need further assistance, please contact Mr. Basharat Iqbal at (916) 324-7343 or Ms. Laura Sullivan McKinney at (916) 327-1525.

Sincerely,



James J. Morgester, Chief  
Compliance Division

cc: Mr. Kenneth Kunaniec, Chairman,  
CAPCOA Vapor Recovery Committee

Mr. Gary Hunter, Manager,  
CARB Compliance Assistance Section

Mr. Donald L. Leininger  
Technical Liaison Manager  
OPW Fueling Components  
Post Office Box 405003  
Cincinnati, Ohio 45240-5003